

Nebraska Department of Water, Energy, and Environment

The National Emission Standards for Hazardous Air Pollutants (NESHAP) and New Source Performance Standards (NSPS) notebooks are to be used as an assistance tool to help comply with state and federal regulations. The Notebooks are not inclusive and are not meant to serve as a substitute for compliance with all applicable regulations. If you have corrections, comments, or questions regarding the notebooks, NSPS, NESHAP or permitting, please contact us at DWEE.AirQuality@nebraska.gov or 402-471-2186.

Air Toxics Notebook

Stationary Combustion Turbines

eCFR 40 CFR Part 63 Subpart YYYY

40 CFR Part 63 Subpart YYYY	Stationary Combustion Turbines
Amendment Dates	03/09/2022 11/19/2020 03/09/2020 04/20/2006 08/18/2004 03/05/2004
Am I Subject to this subpart?	I. This subpart applies to: (A) New stationary combustion turbines with a rated peak power output of at least 1.0 MW, and located at a Major Source of HAPs. II. Not subject to this subpart: (A) Existing turbines. (B) Emergency-use turbines. (C) Turbines located on the North Slope of Alaska. (D) Turbine engine test cells/stands. (E) Duct burners and waste heat recovery units. (6) Loading operations at loading berths that only transfer liquids containing organic HAP as impurities.
Related Rules	NSPS – 40 CFR Part 61 Subpart GG - Stationary Gas Turbines w/ Heat Input at Peak Load >10.7 Gigajoules/Hr (10 MMBtu/hr) Subpart KKKK - Stationary Combustion Turbines
Page Last Updated	07/01/2025