

Nebraska Department of Water, Energy, and Environment

The National Emission Standards for Hazardous Air Pollutants (NESHAP) and New Source Performance Standards (NSPS) notebooks are to be used as an assistance tool to help comply with state and federal regulations. The Notebooks are not inclusive and are not meant to serve as a substitute for compliance with all applicable regulations. If you have corrections, comments, or questions regarding the notebooks, NSPS, NESHAP or permitting, please contact us at DWEE.AirQuality@nebraska.gov or 402-471-2186.

NSPS Notebook

Fossil-Fuel-Fired Steam Generators

eCFR 40 CFR Part 60 Subpart D

40 CFR Part 60 Subpart D	Fossil-Fuel-Fired Steam Generators
Amendment Dates	02/16/2012 01/20/2011 01/28/2009 06/13/2007 12/19/1995
Am I Subject to this subpart?	I. This subpart applies to: (A) Any of the following that commence construction or modification after August 17, 1971: (B) Fossil fuel-fired steam generating units > 73 MW (250 MMBtu/hr) heat input rate; (C) Fossil fuel- and wood residue-fired steam generating units capable of firing fossil fuel at a heat input rate > 73 MW (250 MMBtu/hr) (D) Lignite-fired steam generating units that commenced construction or modification after December 22, 1976 are subject to some requirements (see 40 CFR 60.40(d)) II. Not subject to this subpart: (A) Any facility that commenced construction or modification on or before August 17, 1971 (B) Any facility subject to either NSPS Da or KKKK
Related Rules	NSPS - 40 CFR Part 60 Subpart Da - Electric Utility Steam Generating Units Subpart Db - Industrial-Commercial-Institutional Steam Generating Units Subpart Dc - Small Industrial-Commercial-Institutional Steam Generating Units Subpart KKKK – Standards of Performance for Stationary Combustion Turbines

	NESHAP - 40 CFR Part 63 Subpart DDDDD - Major Source Boilers & Process Heaters Subpart JJJJJJ - Area Source Boilers Subpart UUUUU - Electric Utilities
Page Last Updated	07/01/2025