

Nebraska Department of Water, Energy, and Environment

The National Emission Standards for Hazardous Air Pollutants (NESHAP) and New Source Performance Standards (NSPS) notebooks are to be used as an assistance tool to help comply with state and federal regulations. The Notebooks are not inclusive and are not meant to serve as a substitute for compliance with all applicable regulations. If you have corrections, comments, or questions regarding the notebooks, NSPS, NESHAP or permitting, please contact us at DWEE.AirQuality@nebraska.gov or 402-471-2186.

NSPS Notebook

Stationary Gas Turbines

eCFR 40 CFR Part 60 Subpart GG

40 CFR Part 60 Subpart GG	Stationary Gas Turbines
Amendment Dates	02/27/2014 02/24/2006 07/08/2004 10/17/2000 07/08/2004 11/05/1987 01/27/1982 09/10/1979
Am I Subject to this subpart?	I. This subpart applies to: (A) Stationary gas turbines that meet both of the following conditions: (1) Heat input at peak load of ≥ 10.7 gigajoules (10 MMBtu) per hour, based on the lower heating value of the fuel; (2) Commenced construction, modification, or reconstruction after October 3, 1977 (B) Stationary gas turbines which commenced construction, modification, or reconstruction after February 18, 2005 are subject to NSPS KKKK
Related Rules	NSPS - 40 CFR Part 60 Subpart KKKK - Combustion turbines Subpart Da - Electric Utility Steam Generating Units Subpart Db - Industrial-Commercial-Institutional Steam Generating Units Subpart Dc - Small Industrial-Commercial-Institutional Steam Generating Units
Page Last Updated	07/01/2025