

Nebraska Department of Water, Energy, and Environment

The National Emission Standards for Hazardous Air Pollutants (NESHAP) and New Source Performance Standards (NSPS) notebooks are to be used as an assistance tool to help comply with state and federal regulations. The Notebooks are not inclusive and are not meant to serve as a substitute for compliance with all applicable regulations. If you have corrections, comments, or questions regarding the notebooks, NSPS, NESHAP or permitting, please contact us at DWEE.AirQuality@nebraska.gov or 402-471-2186.

NSPS Notebook

Stationary Compression Ignition Internal Combustion Engines (CI ICE)

eCFR 40 CFR Part 60 Subpart IIII

40 CFR Part 60 Subpart IIII	Stationary Compression Ignition Internal Combustion Engines (CI ICE)
Amendment Dates	08/30/2024 01/24/2023 08/10/2022 06/29/2021 12/04/2020 07/07/2016 02/27/2014 01/30/2013 06/28/2011 07/11/2006
Am I Subject to this subpart?	I. This subpart applies to: (A) Manufacturers of CI ICE with a displacement of < 30 liters/cylinder where the model year is: (1) 2007 or later for non-fire pump engines (2) For fire pump engines: (i) 2011 or later for engines < 100 HP (ii) 2010 or later for engines $100 \leq \text{HP} < 175$ (iii) 2009 or later for engines $175 \leq \text{HP} \leq 750$ (iv) 2008 or later for engines > 750 HP (B) Owners and operators of CI ICE that commenced construction after July 11, 2005, where the CI ICE are: (1) Manufactured after April 1, 2006 and not fire pump engines; (2) Manufactured as a certified National Fire Protection Association fire pump engine after July 1, 2006 (C) Owners and operators of CI ICE that are modified or reconstructed after July 11, 2005

	(D) The date that construction commences is the date the engine is ordered by the owner or operator. The installation date is the date the engine is installed on-site II. Not subject to this subpart: (A) Any CI ICE being tested at a CI ICE test cell/stand. (B) Any CI ICE used for national security (C) Temporary replacement engines that are certified non-road engines and are on-site for less than 1 year.
Related Rules	NSPS - 40 CFR Part 60 Subpart JJJJ - Stationary spark ignition internal combustion Engines (SI ICE) NESHAP - 40 CFR Part 63 Subpart ZZZZ – Reciprocating Internal Combustion Engines (RICE) Subpart PPPPP - Engine test cells & stands
Page Last Updated	07/01/2025