

PUBLIC NOTICE
Nebraska Department of Water, Energy, and Environment
Permitting and Engineering Division

Notice is given to the public, according to Chapter 10 of Title 129 - Nebraska Air Quality Regulations as amended September 28, 2022, that the Department is proposing to issue a Class II operating permit to Stuart Municipal Power Plant (FID# 026807) for operation of three reciprocating internal combustion engines (RICE) at a municipal electrical generation plant (Standard Industrial Classification code 4911 – Electric Services located at 111 West 2nd Street Stuart, Holt County, Nebraska. The potential emissions of regulated air pollutants (in tons per year (tpy)) at this facility will be: 1.90tpy of Particulate Matter (PM), 1.75 tpy of $PM \leq 10$ microns (PM_{10}), 1.70 tpy $PM \leq 2.5$ microns ($PM_{2.5}$), 0.25 tpy Sulfur Dioxide, 98.0 tpy Oxides of Nitrogen, 26.03tpy Carbon Monoxide, 6.13 tpy Volatile Organic Compounds, 0.09 tpy of Propylene (largest quantity individual Hazardous Air Pollutants (HAPs), 0.24 tpy total HAPs, and 861.94 tpy Greenhouse Gases CO_2 equivalents (CO_2e).

Holt County meets the National Ambient Air Quality Standards (NAAQS) for those pollutants subject to a NAAQS and is expected to continue in that status. Holt County is unclassifiable in regard to the state Total Reduced Sulfur (TRS) standards and no significant impact on these standards is expected from this project. No impact is anticipated on habitat for any rare or threatened species.

The Nebraska Department of Water, Energy, and Environment (DWEE) propose to issue a Class II operating permit with specific conditions, based on Title 129, which authorizes the operation of three reciprocating internal combustion engines (RICE) at a municipal electrical generation plant.

The proposed permit and supporting materials are available for inspection by the public Friday, August 21, 2026, through Monday, September 21, 2026, at the office of the DWEE, 245 Fallbrook Boulevard, Suite 100, Lincoln, Nebraska, and electronically at <https://dwee.nebraska.gov/>. Only those provisions that are being revised by this permit action are open for comment at this time. Comments received during this period will be considered prior to the final decision. During this period the applicant, or any interested person or group of persons, may request or petition the Director for a public hearing, the request must state the nature of the issues to be raised and all arguments and factual grounds supporting their position. If a public hearing is granted by the Director, the hearing will be advertised by public notice at least 30 days prior to the hearing.

Inquiries may be made at (402) 471-2186 or dwee.airquality@nebraska.gov. Individuals requiring special accommodations or alternate formats of materials should notify the DWEE by calling (402) 471-2186. TDD users should call (800) 833-7352 and ask the relay operator to call the DWEE at (402) 471-2186. For further information, to submit comments, or request a hearing you may contact the DWEE by email “dwee.airquality@nebraska.gov” or by mail submitted to the attention of David Christensen, Air Quality Program, 245 Fallbrook Blvd., Suite 100, Lincoln, Nebraska 68521.

Please notify the DWEE if auxiliary aids, reasonable accommodations or alternate formats of materials are needed at least one week in advance. Contact phone number is (402) 471-2186. TDD users please call 711 and ask the relay operator to call us at (402) 471-2186.

The DWEE does not discriminate on the basis of race, color, national origin, disability, age, or sex in administration of its programs or activities, and DWEE does not intimidate or retaliate against any individual or group because they have exercised their rights to participate in or oppose actions protected/prohibited by 40 C.F.R. Parts 5 and 7, or for the purpose of interfering with such rights.

Si necesita traducción de documentos al Español, por favor llame a DWEE al (402) 471-2186.