

PUBLIC NOTICE
Nebraska Department of Water, Energy, and Environment
Permitting and Engineering Division

Notice is given to the public, according to Chapter 10 of Title 129 - Nebraska Air Quality Regulations as amended September 28, 2022, that the Department is proposing to issue a Class II operating permit to Village of Callaway (FID# 59060) for the operation of three diesel-fueled internal combustion engines at a municipal power plant (Standard Industrial Classification code 4911) located at 109 S Grand Ave, Callaway, Nebraska. The potential emissions of regulated air pollutants (in tons per year (tpy)) at this facility will be: 6.89 tpy of Particulate Matter (PM), 6.89 tpy of $PM \leq 10$ microns (PM_{10}), 6.89 tpy $PM \leq 2.5$ microns ($PM_{2.5}$), 6.44 tpy Sulfur Dioxide, 98.00 tpy Oxides of Nitrogen (NO_x), 21.11 tpy Carbon Monoxide, 8.00 tpy Volatile Organic Compounds, 0.03 tpy of Formaldehyde (largest quantity individual Hazardous Air Pollutants (HAPs), 0.09 tpy total HAPs, and 3,634.30 tpy Greenhouse Gases CO_2 equivalents (CO_2e).

Custer County meets the National Ambient Air Quality Standards (NAAQS) for those pollutants subject to a NAAQS and is expected to continue in that status. Custer County is unclassifiable in regard to the state Total Reduced Sulfur (TRS) standards and no TRS emissions are expected from this project. No impact is anticipated on habitat for any rare or threatened species.

The Nebraska Department of Water, Energy, and Environment (DWEE) propose to issue a Class II operating permit with specific conditions, based on Title 129, which authorizes limiting NO_x emissions to 98 tpy; limiting the kWh generated to 4,685,280.0 kWh in any 12 consecutive month period; restricting fuel usage to diesel fuel; and requiring recordkeeping and reporting.

The proposed permit and supporting materials are available for inspection by the public Thursday, September 24th, 2026, through Friday, October 23rd, 2026, at the office of the DWEE, 245 Fallbrook Boulevard, Suite 100, Lincoln, Nebraska 68521, and electronically at <https://dwee.nebraska.gov/>. Comments received during this period will be considered prior to the final decision. During this period the applicant, or any interested person or group of persons, may request or petition the Director for a public hearing, the request must state the nature of the issues to be raised and all arguments and factual grounds supporting their position. If a public hearing is granted by the Director, the hearing will be advertised by public notice at least 30 days prior to the hearing.

Inquiries may be made at (402) 471-2186 or dwee.airquality@nebraska.gov. Individuals requiring special accommodations or alternate formats of materials should notify the DWEE by calling (402) 471-2186. TDD users should call (800) 833-7352 and ask the relay operator to call the DWEE at (402) 471-2186. For further information, to submit comments, or request a hearing you may contact the DWEE by email "dwee.airquality@nebraska.gov" or by mail submitted to the attention of David Christensen, Air Quality Program, 245 Fallbrook Blvd., Suite 100, Lincoln, Nebraska 68521.

Please notify the DWEE if auxiliary aids, reasonable accommodations or alternate formats of materials are needed at least one week in advance. Contact phone number is (402) 471-2186. TDD users please call 711 and ask the relay operator to call us at (402) 471-2186.

The DWEE does not discriminate on the basis of race, color, national origin, disability, age, or sex in administration of its programs or activities, and DWEE does not intimidate or retaliate against any individual or group because they have exercised their rights to participate in or oppose actions protected/prohibited by 40 C.F.R. Parts 5 and 7, or for the purpose of interfering with such rights.

Si necesita traducción de documentos al Español, por favor llame a DWEE al (402) 471-2186.